



**CERT**

# DVGW-Baumusterprüfzertifikat

## DVGW type examination certificate

**DG-5112BT0562**

Registriernummer  
registration number

<b>Anwendungsbereich</b> <i>field of application</i>	Produkte der Gasversorgung <i>products of gas supply</i>
<b>Zertifikatinhaber</b> <i>owner of certificate</i>	ALGO S.r.l. Viale Lombardia, 87, I-25031 Capriolo (BS)
<b>Vertreiber</b> <i>distributor</i>	ALGO S.r.l. Viale Lombardia, 87, I-25031 Capriolo (BS)
<b>Produktart</b> <i>product category</i>	Schmier-/Dicht-/Betriebsmittel: Elastomerwerkstoff für Dichtungen in Gasgeräten und -anlagen (5112)
<b>Produktbezeichnung</b> <i>product description</i>	Homogener Elastomerwerkstoff für dynamische und statische Dichtungen
<b>Modell</b> <i>model</i>	N0508-NBR 80
<b>Prüfberichte</b> <i>test reports</i>	Baumusterprüfung: 23-00249-AB01 vom 08.08.2023 (EBI)
<b>Prüfgrundlagen</b> <i>test basis</i>	DIN EN 549 (01.07.2023)

**Ablaufdatum / AZ** 17.12.2028 / 23-0588-GNV  
*date of expiry / file no.*

24.10.2023 Pz A-1/2

Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle  
date, issued by, sheet, head of certification body



Deutsche  
Akkreditierungsstelle  
D-2E-16028-01-01

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wimmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

<b>Typ</b> <i>type</i>	<b>Technische Daten</b> <i>technical data</i>	<b>Bemerkungen</b> <i>remarks</i>
N0508-NBR 80	Härteklasse: H3 Temperaturbereich: -20...80 °C Temperaturklasse: B2	

DVCA

## Important Information Concerning the Validity of Your Certificate

Dear client,

please find enclosed your applied certificate with registration no. DG-5112BT0562. For the certificate you have selected the following surveillance procedure(s):

<b>Model</b>	<b>Production site</b>	<b>Surveillance proc.</b>	<b>Lab.</b>	<b>Deadline</b>
N0508-NBR 80	ALGO S.r.l., Verwaltung I, Capriolo (BS)	Control testing, annually	EBI	24.10.2024

The exact name and address of the test laboratories you will find under: [www.dvgw-cert.com/de/produkte-gas/prueflaboratorien.html](http://www.dvgw-cert.com/de/produkte-gas/prueflaboratorien.html) bzw. unter [www.dvgw-cert.com/de/produkte-wasser/prueflaboratorien.html](http://www.dvgw-cert.com/de/produkte-wasser/prueflaboratorien.html)

According to section 5 of our actual Rules of Procedure for the Certification of Products in the Non-harmonized Sector from January 2013 the certificate holder is obliged to commission regular surveillance measures once DVGW certification is granted. We expect the surveillance procedure to be carried out in time and request the surveillance test report until the above mentioned deadline.

This deadline for the complete surveillance test report must not exceed 3 months. If DVGW CERT GmbH does not receive the complete test report within these 3 months, we must suspend the certificate. Please contact your test laboratory in time and sign a surveillance contract settling regular inspections within the given period.

We must inform you that DVGW CERT GmbH will accept no liability for any damage caused by suspension or withdrawal of certificates due to lack of surveillance in due time.

Instead of control testing you can possibly choose a surveillance procedure of the manufacturer's production quality, including the approval and audit against the product-specific requirements by DVGW CERT GmbH. This depends on the specific regulations in the DVGW rules. Please contact DVGW CERT GmbH for more details.

Thank You  
DVGW CERT GmbH

